
LISTOWEL DRINKING WATER SYSTEM

2023 ANNUAL
SUMMARY REPORT

Municipality of North Perth



Introduction

The treatment and delivery of potable water in Ontario is regulated by the Ministry of the Environment, Conservation and Parks (MECP) under the Safe Drinking Water Act. On June 1, 2003, O. Reg. 170/03 came into effect which prescribes requirements for owners and operators of municipal drinking water systems.

O. Reg. 170/03 requires the owner to produce an Annual Report, under Schedule 11. The Report must include the following:

- A description of the drinking water system including a list of the water treatment chemicals used;
- A summary of any adverse test results or observations and corrective actions;
- A summary of all required test results;
- A description of any major expenses incurred to install, repair or replace equipment.

Every time an Annual Report is prepared the owner of the system shall ensure that effective steps are taken to advise users of water from the system that copies of the report are available, without charge, and how a copy may be obtained.

The Regulation also requires the owner to produce a Summary Report as indicated in Schedule 22.

- The report must list the requirements of the Act, its Regulations, the system's Drinking Water Works Permit, Municipal Drinking Water Licence, and any orders the system failed to meet during the reporting period. The report must also specify the duration of the failure, and for each failure referred to, describe the measures that were taken to correct the failure.
- To enable the Owner to assess the rated capacity of their system to meet existing and future planned water uses, the following information is also required in the report.
 - A summary of the quantities and flow rates of water supplied during the reporting period, including the monthly average and maximum daily flows;
 - A comparison of the summary to the rated capacity and flow rates approved in the system's Permit To Take Water, Drinking Water Works Permit and Municipal Drinking Water Licence



Part 1 - ANNUAL REPORT (as required by O. Reg. 170/03, Section 11)

Drinking-Water System Number:	220000512
Drinking-Water System Name:	Listowel Drinking Water System
Drinking-Water System Owner:	Municipality of North Perth
Drinking-Water System Category:	Large Municipal Residential
Municipal Drinking Water Licence:	091-103 (Issue #4)
Drinking Water Works Permit:	091-203 (Issue #4)
Permit to Take Water;	P-300-5141584896
Period being reported:	January 1 to December 31, 2023

Complete if your Category is Large Municipal Residential or Small Municipal Residential	Complete for all other Categories
<p><i>Does your Drinking-Water System serve more than 10,000 people?</i></p> <p><input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p>	<p><i>Number of Designated Facilities served: 0</i></p>
<p><i>Is your annual report available to the public at no charge on a web site on the Internet?</i></p> <p><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p>	<p><i>Did you provide a copy of your annual report to all Designated Facilities you serve?</i></p> <p><input type="checkbox"/> Yes <input type="checkbox"/> No</p>
<p><i>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</i></p> <p>Municipal Office and Municipality of North Perth Website</p>	<p><i>Number of Interested Authorities you report to: 0</i></p> <p><i>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility?</i></p> <p><input type="checkbox"/> Yes <input type="checkbox"/> No</p>

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:	
Drinking Water System Name	Drinking Water System Number
N/A	



Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
N/A

Indicate how you notified system users that your annual report is available and is free of charge.		
<input checked="" type="checkbox"/> Public access/notice via the web	<input checked="" type="checkbox"/> Public access/notice via Government Office	<input type="checkbox"/> Public access/notice via a newspaper
<input checked="" type="checkbox"/> Public access/notice via Public Request	<input type="checkbox"/> Public access/notice via a Public Library	<input type="checkbox"/> Public access/notice via Other Method _____

Describe your Drinking Water System

The Listowel Drinking Water System is owned and operated by the Municipality of North Perth and provides a potable water supply to the residents of Listowel.

The Listowel Drinking Water System consists of three (3) ground water wells automatically controlled by a Supervisory Control and Data Acquisition (SCADA) system. System pressure is maintained by an elevated water tower at 580 Main St. West, with a maximum capacity of 3182m³. Predetermined water level set points automatically start and stop the well pumps. Two chemical feed pumps at each well also start automatically adding sodium hypochlorite and sodium silicate to the water.

The first chemical added is sodium hypochlorite (liquid chlorine). It is used to kill any disease-causing organisms (disinfect) that may be present in the water. It is important to add enough of this chemical to maintain a free chlorine residual throughout the water distribution system. A chlorine analyzer ensures a sufficient residual is maintained in the water entering the distribution. The second chemical added is sodium silicate. It is used as a sequestering agent to prevent iron from oxidizing thereby minimizing the rust formation in the water.

List all water treatment chemicals used over this reporting period

- Liquid Chlorine 12% - NSF certified
- Sodium Silicate - NSF certified



Listowel Drinking Water System
2023 Annual and Summary Report

Please provide a brief description and a breakdown of monetary expenses incurred
<ul style="list-style-type: none"> • Water Meter Replacement project and new AMI reading system \$1,700,000. • Listowel Water Tower Interior and Exterior Cleaning, Inspection, and safety upgrades \$34,000

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre				
Incident Date	Parameter	Result	Corrective Action Date	Corrective Action
Jan 16, 2023	Arsenic	11.4 ug/L	Jan 18/23	Resampled and tested as per HPPH and Regulation. Test result of 6.4 ug/L, which is below max of 10 ug/L. Consistent with historical results for well 4.
May 19/23	NDOGN - Overgrowth on distribution sample	N/A	May 23/23	Resampled and retested at source, upstream and downstream. Tested residuals where samples taken, 0.76 – 0.92 mg/L



Listowel Drinking Water System
2023 Annual and Summary Report

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period					
	Number of Samples	Range of E. Coli Results (Min-Max)	Range of Total Coliform Results (Min-Max)	Number of HPC Samples	Range of HPC Results (Min-Max)
Well 4 - Raw	50	0-0	0-0	N/A	N/A
Well 5 - Raw	52	0-0	0-0	N/A	N/A
Well 6 - Raw	52	0-0	0-0	N/A	N/A
Well 4 - Treated	50	0-0	0-0	50	0-47
Well 5 - Treated	52	0-0	0-0	52	0-1
Well 6 Treated	52	0-0	0-0	52	0-3
Distribution 1 - Davidson Ave North	52	0-0	0-0	52	0-9
Distribution 2 - Palace End Blow Off	52	0-0	0-0	52	0-29
Distribution 3 - Listowel Fire Hall	52	0-0	0-0	52	0-15
Distribution 4 - Community Garden	52	0-0	0-0	52	0-74
Distribution 5 - Scott St. West Blow Off	54	0-0	0-0	52	0-39
Other – Distribution – 700 Rogers Road	2	0-0	0-0	N/A	N/A
Other Distribution – 580 Albert Ave. North	2	0-0	0-0	N/A	N/A



Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report			
	Number of Samples	Range of Results (Min-Max)	Units
Well 4 -Raw Turbidity – grab sample	12	0.16 – 0.41	NTU
Well 5 – Raw Turbidity – grab sample	12	0.15 – 0.43	NTU
Well 6 – Raw Turbidity – grab sample	12	0.16 – 0.33	NTU
Well 4 - Free Chlorine Residual – continuous monitor at well house	8,760	0.0* - 2.50	mg/L
Well 5 - Free Chlorine Residual – continuous monitor at well house	8,760	0.0* - 1.58	mg/L
Well 6 - Free Chlorine Residual – continuous monitor at well house	8,760	0.0* - 2.15	mg/L
Free Chlorine Residual – grab samples in distribution system	474	0.61 – 1.08	mg/L

*Value due to operational maintenance



Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument				
Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A				

Additional water information
<p>Hardness and Iron may affect the appearance of water. Iron is a naturally occurring mineral commonly found in ground water wells throughout Ontario. Water with higher levels of iron can stain fixtures and clothing. Iron testing is not required by the Safe Drinking Water Act as it is considered an aesthetic(visual) concern, not a health concern.</p> <p>Levels of iron less than 0.30 mg/L are not considered to cause aesthetic problems such as discoloured water. Sodium silicate is added to the raw water to keep the iron in suspension. The average iron level in raw water tested in 2023 was 0.82 mg/L. The average iron level in the distribution water tested in 2023 was 0.56 mg/L.</p> <p>Many households have water softeners to help reduce white calcium deposits and improve the efficiency of soaps and reduce iron levels. The water hardness for North Perth Drinking Water Systems is approximately 265 mg/L (15 grains/gallon).</p>

Inorganic Testing – Well 4

Summary of Inorganic parameters tested during this reporting period or the most recent sample results				
Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Aug 9/21	ND	µg/L	No
Arsenic – Well back in service after 2022 maintenance	Jan 16/23	11.4	µg/L	Yes
Arsenic – (retest)	Jan 18/23	6.4	µg/L	No
Arsenic – Q1	Feb 14/23	6.4	µg/L	No
Arsenic – Q2	May 17/23	5.9	µg/L	No
Arsenic – Q3	Aug 15/23	6.1	µg/L	No
Arsenic – Q4	Nov 13/23	6.0	µg/L	No
Barium	Aug 9/21	65	µg/L	No



Listowel Drinking Water System 2023 Annual and Summary Report

Boron	Aug 9/21	ND	µg/L	No
Cadmium	Aug 9/21	ND	µg/L	No
Chromium	Aug 9/21	ND	µg/L	No
Mercury	Aug 9/21	ND	µg/L	No
Selenium	Aug 9/21	ND	µg/L	No
Sodium	Aug 15/23	16.9	mg/L	No
Uranium	Aug 9/21	ND	µg/L	No
Fluoride	Aug 15/23	0.939	mg/L	No
Nitrite – Q1	Feb 14/23	ND	mg/L	No
Nitrite – Q2	May 17/23	ND	mg/L	No
Nitrite – Q3	Aug 15/23	ND	mg/L	No
Nitrite – Q4	Nov 13/23	ND	mg/L	No
Nitrate – Q1	Feb 14/23	ND	mg/L	No
Nitrate – Q2	May 17/23	ND	mg/L	No
Nitrate – Q3	Aug 15/23	ND	mg/L	No
Nitrate – Q4	Nov 13/23	ND	mg/L	No

ND = Not detected

Inorganic Testing – Well 5

Summary of Inorganic parameters tested during this reporting period or the most recent sample results				
Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Aug 9/21	ND	µg/L	No
Arsenic	Aug 9/21	4.9	µg/L	No
Barium	Aug 9/21	73	µg/L	No
Boron	Aug 9/21	ND	µg/L	No
Cadmium	Aug 9/21	ND	µg/L	No
Chromium	Aug 9/21	ND	µg/L	No
Mercury	Aug 9/21	ND	µg/L	No
Selenium	Aug 9/21	ND	µg/L	No
Sodium	Aug 15/23	18.3	mg/L	No
Uranium	Aug 9/21	ND	µg/L	No
Fluoride	Aug 15/23	0.944	mg/L	Yes
Nitrite – Q1	Feb 14/23	ND	mg/L	No
Nitrite – Q2	May 17/23	ND	mg/L	No
Nitrite – Q3	Aug 15/23	ND	mg/L	No
Nitrite – Q4	Nov 13/23	ND	mg/L	No
Nitrate – Q1	Feb 14/23	ND	mg/L	No



Listowel Drinking Water System 2023 Annual and Summary Report

Nitrate – Q2	May 17/23	ND	mg/L	No
Nitrate – Q3	Aug 15/23	ND	mg/L	No
Nitrate – Q4	Nov 13/23	ND	mg/L	No

ND = Not detected

Inorganic Testing – Well 6

Summary of Inorganic parameters tested during this reporting period or the most recent sample results				
Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Aug 9/21	ND	µg/L	No
Arsenic	Aug 9/21	3.7	µg/L	No
Barium	Aug 9/21	92	µg/L	No
Boron	Aug 9/21	58	µg/L	No
Cadmium	Aug 9/21	ND	µg/L	No
Chromium	Aug 9/21	ND	µg/L	No
Mercury	Aug 9/21	ND	µg/L	No
Selenium	Aug 9/21	ND	µg/L	No
Sodium	Aug 15/23	18.4	mg/L	No
Uranium	Aug 9/21	ND	µg/L	No
Fluoride	Aug 15/23	1.30	mg/L	Yes
Nitrite – Q1	Feb 14/23	ND	mg/L	No
Nitrite – Q2	May 17/23	ND	mg/L	No
Nitrite – Q3	Aug 15/23	ND	mg/L	No
Nitrite – Q4	Nov 13/23	ND	mg/L	No
Nitrate – Q1	Feb 14/23	ND	mg/L	No
Nitrate – Q2	May 17/23	ND	mg/L	No
Nitrate – Q3	Aug 15/23	ND	mg/L	No
Nitrate – Q4	Nov 13/23	ND	mg/L	No

ND = Not detected



Lead Testing Results

Summary of Lead Results during this reporting period (Winter: Dec 15 – April 15; Summer: June 15 - Oct 15)					
Sampling Period	Location	pH	Alkalinity (mg/L)	Lead (ug/L)	Exceedance
Feb 14/23	Distribution – Palace St. E Blow Off	8.03	230	<1.0	No
Feb 14/23	Distribution – Community Garden Blow Off	8.05	233	<1.0	No
Feb 14/23	Distribution – 755 Scott St. E Blow Off	8.02	234	2.0	No
Aug 15/23	Distribution – Palace St. E Blow Off	8.06	230	<1.0	No
Aug 15/23	Distribution – Community Garden Blow Off	8.09	232	<1.0	No
Aug 15/23	Distribution – 755 Scott St. E Blow Off	8.14	234	<1.0	No

Listowel qualified for reduced Lead sampling in 2023

Organic Testing – Well 4

Summary of Organic parameters tested during this reporting period or the most recent sample results				
Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Aug 9/21	ND	µg/L	No
Atrazine + N-dealkylated metabolites	Aug 9/21	ND	µg/L	No
Azinphos-methyl	Aug 9/21	ND	µg/L	No
Benzene	Aug 9/21	ND	µg/L	No
Benzo(a)pyrene	Aug 9/21	ND	µg/L	No
Bromoxynil	Aug 9/21	ND	µg/L	No



Listowel Drinking Water System
2023 Annual and Summary Report

Summary of Organic parameters tested during this reporting period or the most recent sample results				
Carbaryl	Aug 9/21	ND	µg/L	No
Carbofuran	Aug 9/21	ND	µg/L	No
Carbon Tetrachloride	Aug 9/21	ND	µg/L	No
Chlorpyrifos	Aug 9/21	ND	µg/L	No
Diazinon	Aug 9/21	ND	µg/L	No
Dicamba	Aug 9/21	ND	µg/L	No
1,2-Dichlorobenzene	Aug 9/21	ND	µg/L	No
1,4-Dichlorobenzene	Aug 9/21	ND	µg/L	No
1,2-Dichloroethane	Aug 9/21	ND	µg/L	No
1,1-Dichloroethylene (vinylidene chloride)	Aug 9/21	ND	µg/L	No
Dichloromethane	Aug 9/21	ND	µg/L	No
2-4 Dichlorophenol	Aug 9/21	ND	µg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Aug 9/21	ND	µg/L	No
Diclofop-methyl	Aug 9/21	ND	µg/L	No
Dimethoate	Aug 9/21	ND	µg/L	No
Diquat	Aug 9/21	ND	µg/L	No
Diuron	Aug 9/21	ND	µg/L	No
Glyphosate	Aug 9/21	ND	µg/L	No
HAA (running annual average)	2023	7.23	µg/L	No
Malathion	Aug 9/21	ND	µg/L	No
Metolachlor	Aug 9/21	ND	µg/L	No
Metribuzin	Aug 9/21	ND	µg/L	No
Monochlorobenzene	Aug 9/21	ND	µg/L	No
Paraquat	Aug 9/21	ND	µg/L	No
Pentachlorophenol	Aug 9/21	ND	µg/L	No
Phorate	Aug 9/21	ND	µg/L	No
Picloram	Aug 9/21	ND	µg/L	No
Polychlorinated Biphenyls(PCB)	Aug 9/21	ND	µg/L	No
Prometryne	Aug 9/21	ND	µg/L	No
Simazine	Aug 9/21	ND	µg/L	No
THM (running annual average)	2023	13.025	µg/L	No
Terbufos	Aug 9/21	ND	µg/L	No
Tetrachloroethylene	Aug 9/21	ND	µg/L	No
2,3,4,6-Tetrachlorophenol	Aug 9/21	ND	µg/L	No
Triallate	Aug 9/21	ND	µg/L	No
Trichloroethylene	Aug 9/21	ND	µg/L	No
2,4,6-Trichlorophenol	Aug 9/21	ND	µg/L	No



Summary of Organic parameters tested during this reporting period or the most recent sample results				
Trifluralin	Aug 9/21	ND	µg/L	No
Vinyl Chloride	Aug 9/21	ND	µg/L	No
2 methyl-4-chlorophenoxyacetic acid (MCPA) Reported as MCPA on analysis	Aug 9/21	ND	µg/L	No

*ND = Not detected

Organic Testing – Well 5

Summary of Organic parameters tested during this reporting period or the most recent sample results				
Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Aug 9/21	ND	µg/L	No
Atrazine + N-dealkylated metabolites	Aug 9/21	ND	µg/L	No
Azinphos-methyl	Aug 9/21	ND	µg/L	No
Benzene	Aug 9/21	ND	µg/L	No
Benzo(a)pyrene	Aug 9/21	ND	µg/L	No
Bromoxynil	Aug 9/21	ND	µg/L	No
Carbaryl	Aug 9/21	ND	µg/L	No
Carbofuran	Aug 9/21	ND	µg/L	No
Carbon Tetrachloride	Aug 9/21	ND	µg/L	No
Chlorpyrifos	Aug 9/21	ND	µg/L	No
Diazinon	Aug 9/21	ND	µg/L	No
Dicamba	Aug 9/21	ND	µg/L	No
1,2-Dichlorobenzene	Aug 9/21	ND	µg/L	No
1,4-Dichlorobenzene	Aug 9/21	ND	µg/L	No
1,2-Dichloroethane	Aug 9/21	ND	µg/L	No
1,1-Dichloroethylene (vinylidene chloride)	Aug 9/21	ND	µg/L	No
Dichloromethane	Aug 9/21	ND	µg/L	No
2-4 Dichlorophenol	Aug 9/21	ND	µg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Aug 9/21	ND	µg/L	No
Diclofop-methyl	Aug 9/21	ND	µg/L	No
Dimethoate	Aug 9/21	ND	µg/L	No
Diquat	Aug 9/21	ND	µg/L	No
Diuron	Aug 9/21	ND	µg/L	No



Listowel Drinking Water System
2023 Annual and Summary Report

Summary of Organic parameters tested during this reporting period or the most recent sample results				
Glyphosate	Aug 9/21	ND	µg/L	No
HAA (running annual average)	2023	7.23	µg/L	No
Malathion	Aug 9/21	ND	µg/L	No
Metolachlor	Aug 9/21	ND	µg/L	No
Metribuzin	Aug 9/21	ND	µg/L	No
Monochlorobenzene	Aug 9/21	ND	µg/L	No
Paraquat	Aug 9/21	ND	µg/L	No
Pentachlorophenol	Aug 9/21	ND	µg/L	No
Phorate	Aug 9/21	ND	µg/L	No
Picloram	Aug 9/21	ND	µg/L	No
Polychlorinated Biphenyls(PCB)	Aug 9/21	ND	µg/L	No
Prometryne	Aug 9/21	ND	µg/L	No
Simazine	Aug 9/21	ND	µg/L	No
THM (running annual average)	2023	13.025	µg/L	No
Terbufos	Aug 9/21	ND	µg/L	No
Tetrachloroethylene	Aug 9/21	ND	µg/L	No
2,3,4,6-Tetrachlorophenol	Aug 9/21	ND	µg/L	No
Triallate	Aug 9/21	ND	µg/L	No
Trichloroethylene	Aug 9/21	ND	µg/L	No
2,4,6-Trichlorophenol	Aug 9/21	ND	µg/L	No
Trifluralin	Aug 9/21	ND	µg/L	No
Vinyl Chloride	Aug 9/21	ND	µg/L	No
2 methyl-4-chlorophenoxyacetic acid (MCPA) Reported as MCPA on analysis	Aug 9/21	ND	µg/L	No

*ND = Not detected

Organic Testing – Well 6

Summary of Organic parameters tested during this reporting period or the most recent sample results				
Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Aug 9/21	ND	µg/L	No
Atrazine + N-dealkylated metabolites	Aug 9/21	ND	µg/L	No
Azinphos-methyl	Aug 9/21	ND	µg/L	No
Benzene	Aug 9/21	ND	µg/L	No



Listowel Drinking Water System
2023 Annual and Summary Report

Summary of Organic parameters tested during this reporting period or the most recent sample results				
Benzo(a)pyrene	Aug 9/21	ND	µg/L	No
Bromoxynil	Aug 9/21	ND	µg/L	No
Carbaryl	Aug 9/21	ND	µg/L	No
Carbofuran	Aug 9/21	ND	µg/L	No
Carbon Tetrachloride	Aug 9/21	ND	µg/L	No
Chlorpyrifos	Aug 9/21	ND	µg/L	No
Diazinon	Aug 9/21	ND	µg/L	No
Dicamba	Aug 9/21	ND	µg/L	No
1,2-Dichlorobenzene	Aug 9/21	ND	µg/L	No
1,4-Dichlorobenzene	Aug 9/21	ND	µg/L	No
1,2-Dichloroethane	Aug 9/21	ND	µg/L	No
1,1-Dichloroethylene (vinylidene chloride)	Aug 9/21	ND	µg/L	No
Dichloromethane	Aug 9/21	ND	µg/L	No
2-4 Dichlorophenol	Aug 9/21	ND	µg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Aug 9/21	ND	µg/L	No
Diclofop-methyl	Aug 9/21	ND	µg/L	No
Dimethoate	Aug 9/21	ND	µg/L	No
Diquat	Aug 9/21	ND	µg/L	No
Diuron	Aug 9/21	ND	µg/L	No
Glyphosate	Aug 9/21	ND	µg/L	No
HAA (running annual average)	2023	7.23	µg/L	No
Malathion	Aug 9/21	ND	µg/L	No
Metolachlor	Aug 9/21	ND	µg/L	No
Metribuzin	Aug 9/21	ND	µg/L	No
Monochlorobenzene	Aug 9/21	ND	µg/L	No
Paraquat	Aug 9/21	ND	µg/L	No
Pentachlorophenol	Aug 9/21	ND	µg/L	No
Phorate	Aug 9/21	ND	µg/L	No
Picloram	Aug 9/21	ND	µg/L	No
Polychlorinated Biphenyls(PCB)	Aug 9/21	ND	µg/L	No
Prometryne	Aug 9/21	ND	µg/L	No
Simazine	Aug 9/21	ND	µg/L	No
THM (running annual average)	2023	13.025	µg/L	No
Terbufos	Aug 9/21	ND	µg/L	No
Tetrachloroethylene	Aug 9/21	ND	µg/L	No
2,3,4,6-Tetrachlorophenol	Aug 9/21	ND	µg/L	No
Triallate	Aug 9/21	ND	µg/L	No



Listowel Drinking Water System
2023 Annual and Summary Report

Summary of Organic parameters tested during this reporting period or the most recent sample results				
Trichloroethylene	Aug 9/21	ND	µg/L	No
2,4,6-Trichlorophenol	Aug 9/21	ND	µg/L	No
Trifluralin	Aug 9/21	ND	µg/L	No
Vinyl Chloride	Aug 9/21	ND	µg/L	No
2 methyl-4-chlorophenoxyacetic acid (MCPA) Reported as MCPA on analysis	Aug 9/21	ND	µg/L	No

*ND = Not detected

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.				
Parameter	Sample Date	Result Value	Unit of Measure	ODWS Standard
Fluoride – Well 4	Aug 15/23	0.939	mg/L	1.5
Fluoride – Well 5	Aug 15/23	0.944	mg/L	1.5
Fluoride – Well 6	Aug 15/23	1.30	mg/L	1.5
Arsenic – Well back in service after 2022 maintenance – Well 4	Jan 16/23	11.4	µg/L	10
Arsenic – (retest) – Well 4	Jan 18/23	6.4	µg/L	10
Arsenic – Q1 – Well 4	Feb 14/23	6.4	µg/L	10
Arsenic – Q2 – Well 4	May 17/23	5.9	µg/L	10
Arsenic – Q3 – Well 4	Aug 15/23	6.1	µg/L	10
Arsenic – Q4 – Well 4	Nov 13/23	6.0	µg/L	10

Note: Fluoride is naturally occurring in the Atwood Drinking Water Supply. For more information on fluoride visit Huron Perth Public Health Unit at:

<https://www.hpph.ca/en/health-matters/water.aspx>



Part 2 – SUMMARY REPORT (as required by O. Reg. 170/03, Schedule 22)

Non-Compliance with Legislations, Regulations, Approvals & Orders

The Atwood Drinking Water System is governed by, and must operate in accordance with, the following Acts and Regulations:

- Safe Drinking Water Act 2002;
 - O. Reg 128/04 – Certification of Drinking Water System Operators
 - O. Reg 170/03 – Drinking Water Systems
 - O. Reg 169/03 – Ontario Drinking Water Quality Standards
- Environmental Protection Act, where applicable;
- Clean Water Act, where applicable;
- Municipal Drinking Water Licence - 091-101;
- Drinking Water Works Permit - 091-201;
- Permit to Take Water – 1771-9UVR3Y

During this period, the Facility was operated in full compliance with the Act, the regulations and the Facility’s license and permit save and except for the following:

Requirement	Duration of Failure	Measures to Correct the Failure
All continuous analyzers were not calibrated, maintained, and operated, in accordance with the manufacturer’s instructions or the regulation.	Reporting Period	Standard Operating Procedure #11 – Calibration of On-line Chlorine Analyzers has been amended to ensure the accuracy and frequency of continuous free chlorine analyzers are maintained as required. Additionally, all portable free chlorine meters used for the calibration of online analyzers are now being verified on a weekly basis, as recommended.



System Capability

WELL 4						
Month	Average Flow (m³/d)	Maximum Flow (m³/d)	Total Monthly Flow (m³/d)	Maximum Flow Rate (L/min)	System Capacity	Approved Flow Rate
January	388.31	842.95	12037.69	2037.87	3,273.1 m ³ /day	2,273 L/min
February	728.54	901.37	20399.13	2024.42		
March	729.84	902.30	22624.92	2245.19		
April	756.11	845.00	22683.38	2055.56		
May	799.65	1777.00	24789.00	2052.44		
June	892.13	1127.00	26764.00	2048.22		
July	814.58	1280.00	25252.00	2039.52		
August	786.87	877.00	24393.00	2070.35		
September	933.27	2374.00	27998.00	2190.68		
October	831.16	1095.00	25766.00	2076.91		
November	728.13	939.00	23464.00	1998.78		
December	768.65	934.00	23828.00	1994.09		
Average	763.10		23333.26	2069.50		
Maximum		1777.00	27998.00	2245.19		
% of Capacity	23.31	54.29				



Listowel Drinking Water System
2023 Annual and Summary Report

WELL 5						
Month	Average Flow (m³/d)	Maximum Flow (m³/d)	Total Monthly Flow (m³/d)	Maximum Flow Rate (L/min)	System Capacity	Approved Flow Rate
January	857.63	1208.30	26586.40	1817.25	3,273.1 m ³ /day	2,273 L/min
February	676.29	851.30	18936.00	1812.05		
March	722.45	1052.60	22395.80	1814.20		
April	736.97	837.00	22109.10	2241.01		
May	984.90	1707.00	30532.00	2047.16		
June	868.33	1089.00	26050.00	2033.33		
July	796.32	1216.00	24686.00	2064.81		
August	769.71	857.00	23861.00	2065.77		
September	925.50	2584.00	27765.00	2039.01		
October	804.97	1049.00	24954.00	1968.54		
November	774.50	918.00	23235.00	1968.25		
December	762.65	927.00	23611.00	2010.05		
Average	806.69		24560.11	1990.12		
Maximum		2584.00	30532.00	2241.01		
% of Capacity	24.65	78.95				



Listowel Drinking Water System
2023 Annual and Summary Report

WELL 6						
Month	Average Flow (m³/d)	Maximum Flow (m³/d)	Total Monthly Flow (m³/d)	Maximum Flow Rate (L/min)	System Capacity	Approved Flow Rate
January	852.20	1166.60	26418.30	1817.91	3,273.1 m ³ /day	2,273 L/min
February	683.94	851.40	19150.40	1810.51		
March	720.45	1053.70	22333.80	1812.35		
April	732.83	835.00	21984.80	2224.01		
May	999.71	1746.00	30991.00	2034.08		
June	900.73	1129.00	27022.00	2047.85		
July	806.26	1257.00	24994.00	2059.84		
August	778.45	870.00	24132.00	2061.82		
September	901.80	2506.00	27054.00	2051.09		
October	831.42	1092.00	25774.00	1987.38		
November	798.97	937.00	23969.00	1986.99		
December	762.90	936.00	23650.00	1997.55		
Average	814.14		24789.44	1990.95		
Maximum		2506.00	30991.00	2224.01		
% of Capacity	24.87	76.56				



Listowel Drinking Water System
2023 Annual and Summary Report

LISTOWEL WELL SUPPLY – ALL WELLS					
Month	Average Flow (m³/d)	Maximum Flow (m³/d)	Total Monthly Flow (m³)	System Capacity	Approved Flow Rate
January	2098.14	2526.30	65042.39	9,819 m ³ /day	Well 4: 2,273 L/min Well 5: 2,273 L/min Well 6: 2,273 L/min
February	2088.77	2604.07	58485.53		
March	2172.73	2595.68	67354.52		
April	2225.91	2452.00	66777.28		
May	2784.26	5230.00	86132.00		
June	2661.20	3345.00	79836.00		
July	2417.16	3753.00	74932.00		
August	2335.03	2590.00	72386.00		
September	2780.57	6331.00	82817.00		
October	2467.55	3236.00	76494.00		
November	2355.60	2788.00	70688.00		
December	2293.19	2797.00	71809.00		
Average	2390.01		72729.48		
Maximum		6331.00	82817.00		
% of Capacity	24.34	64.48			