
GOWANSTOWN DRINKING WATER SYSTEM

2025 ANNUAL
SUMMARY REPORT

Municipality of North Perth



Introduction

The treatment and delivery of potable water in Ontario is regulated by the Ministry of the Environment, Conservation and Parks (MECP) under the Safe Drinking Water Act. On June 1, 2003, O. Reg. 170/03 came into effect which prescribes requirements for owners and operators of municipal drinking water systems.

O. Reg. 170/03 requires the owner to produce an Annual Report, under Schedule 11. The Report must include the following:

- A description of the drinking water system including a list of the water treatment chemicals used;
- A summary of any adverse test results or observations and corrective actions;
- A summary of all required test results;
- A description of any major expenses incurred to install, repair, or replace equipment.

Every time an Annual Report is prepared the owner of the system shall ensure that effective steps are taken to advise users of water from the system that copies of the report are available, without charge, and how a copy may be obtained.

The Regulation also requires the owner to produce a Summary Report as indicated in Schedule 22.

- The report must list the requirements of the Act, its Regulations, the system's Drinking Water Works Permit, Municipal Drinking Water Licence, and any orders the system failed to meet during the reporting period. The report must also specify the duration of the failure, and for each failure referred to, describe the measures that were taken to correct the failure.
- To enable the Owner to assess the rated capacity of their system to meet existing and future planned water uses, the following information is also required in the report.
 - A summary of the quantities and flow rates of water supplied during the reporting period, including the monthly average and maximum daily flows;
 - A comparison of the summary to the rated capacity and flow rates approved in the system's Permit to Take Water, Drinking Water Works Permit and Municipal Drinking Water Licence.



Part 1 - ANNUAL REPORT (as required by O. Reg. 170/03, Section 11)

Drinking-Water System Number:	220003975
Drinking-Water System Name:	Gowanstown Subdivision Drinking Water System
Drinking-Water System Owner:	Municipality of North Perth
Drinking-Water System Category:	Small Municipal Residential
Municipal Drinking Water Licence	091-102 (Issue #6)
Drinking Water Works Permit	091-202 (Issue #5)
Period being reported:	January 1 to December 31, 2025

Complete if your Category is Large Municipal Residential or Small Municipal Residential	Complete for all other Categories
<p><i>Does your Drinking-Water System serve more than 10,000 people?</i></p> <p><input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p>	<p><i>Number of Designated Facilities served: 0</i></p>
<p><i>Is your annual report available to the public at no charge on a web site on the Internet?</i></p> <p><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p>	<p><i>Did you provide a copy of your annual report to all Designated Facilities you serve?</i></p> <p><input type="checkbox"/> Yes <input type="checkbox"/> No</p>
<p><i>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</i></p> <p>Municipal Office and Municipality of North Perth Website</p>	<p><i>Number of Interested Authorities you report to: 0</i></p> <p><i>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility?</i></p> <p><input type="checkbox"/> Yes <input type="checkbox"/> No</p>

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:	
Drinking Water System Name	Drinking Water System Number
N/A	



Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
N/A

Indicate how you notified system users that your annual report is available and is free of charge.		
<input checked="" type="checkbox"/> Public access/notice via the web	<input checked="" type="checkbox"/> Public access/notice via Government Office	<input type="checkbox"/> Public access/notice via a newspaper
<input checked="" type="checkbox"/> Public access/notice via Public Request	<input type="checkbox"/> Public access/notice via a Public Library	<input type="checkbox"/> Public access/notice via Other Method _____

Describe your Drinking Water System
<p>The Gowanstown Subdivision Drinking Water System consists of one ground water well housed in a concrete block building located west of Maple Lane. Two 454-liter pre-charged pressure tanks provide pressure to the distribution system when the well pump is not operating. Predetermined pressure set points automatically start and stop the well pumps. Two chemical feed pumps operate with the well pump on a rotating duty basis, automatically adding predetermined quantities of sodium hypochlorite. A third pump adds sodium silicate to the water.</p> <p>The first chemical added is sodium hypochlorite (liquid chlorine). It is used to kill any disease-causing organisms (disinfect) that may be present in the water. It is important to add enough of this chemical to maintain a free chlorine residual throughout the water distribution system. A chlorine analyzer has been installed to ensure a sufficient residual is maintained in the water entering the distribution. The second chemical added is sodium silicate. It is used as a sequestering agent to prevent iron from oxidizing thereby minimizing the rust formation in the water.</p>

List all water treatment chemicals used over this reporting period
<ul style="list-style-type: none"> • Liquid Chlorine 12% - NSF certified • Sodium Silicate - NSF certified



Please provide a brief description and a breakdown of monetary expenses incurred

No significant monetary expenses incurred in 2025.

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Corrective Action Date	Corrective Action
Jan 22/25	Low Pressure caused by the generator not starting during a power failure, due to a battery issue.	4.51psi	Jan 22/25	New battery was purchased, and charger was replaced on the generator

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period

	Number of Samples	Range of E. Coli Results (Min-Max)	Range of Total Coliform Results (Min-Max)	Number of HPC Samples	Range of HPC Results (Min-Max)
Raw	12	0-0	0-0	N/A	N/A
Treated	N/A	N/A	N/A	N/A	N/A
Distribution	12	0-0	0-0	12	0 - 4



Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report			
	Number of Samples	Range of Results (Min-Max)	Units
Raw Turbidity – grab sample	12	0.24 – 0.47	NTU
Treated Turbidity – grab sample	12	0.23 – 0.47	NTU
Free Chlorine Residual – continuous monitor at well house	8,760	0.0* - 3.58*	mg/L
Free Chlorine Residual – grab sample in distribution system	17	1.26 – 1.83	mg/L

*Value due to operational maintenance

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument				
Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A				

Additional water information
N/A



Inorganic Testing

Summary of Inorganic parameters tested during this reporting period or the most recent sample results				
Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Aug 15/23	ND	µg/L	No
Arsenic – Q1	Feb 10/25	9.2	µg/L	No
Arsenic – Q2	May 12/25	8.8	µg/L	No
Arsenic – Q3	Aug 11/25	9.2	µg/L	No
Arsenic – Q4	Nov 10/25	9.1	µg/L	Yes
Barium	Aug 15/23	53	µg/L	No
Boron	Aug 15/23	ND	µg/L	No
Cadmium	Aug 15/23	ND	µg/L	No
Chromium	Aug 15/23	ND	µg/L	No
Mercury	Aug 15/23	ND	µg/L	No
Selenium	Aug 15/23	ND	µg/L	No
Sodium	Aug 15/23	14.9	mg/L	No
Uranium	Aug 15/23	ND	µg/L	No
Fluoride	Aug 15/23	0.501	mg/L	No
Nitrite – Q1	Feb 10/25	ND	mg/L	No
Nitrite – Q2	May 12/25	ND	mg/L	No
Nitrite – Q3	Aug 11/25	ND	mg/L	No
Nitrite – Q4	Nov 10/25	ND	mg/L	No
Nitrate – Q1	Feb 10/25	ND	mg/L	No
Nitrate – Q2	May 12/25	ND	mg/L	No
Nitrate – Q3	Aug 11/25	ND	mg/L	No
Nitrate – Q4	Nov 10/25	ND	mg/L	No

ND = Not detected



Lead Testing Results

Summary of Lead Results during this reporting period (Winter: Dec 15 – April 15; Summer: June 15 - Oct 15)					
Sampling Period	Location	pH	Alkalinity (mg/L)	Lead (ug/L)	Exceedance
Feb 10/2025	Blow off – Maple Lane	7.90	226	N/A	No
Aug 11/2025	Blow off – Maple Lane	7.80	221	N/A	No

Gowanstown qualified for reduced Lead sampling in 2025

Organic Testing

Summary of Organic parameters tested during this reporting period or the most recent sample results				
Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Aug 15/23	ND	µg/L	No
Atrazine + N-dealkylated metabolites	Aug 15/23	ND	µg/L	No
Azinphos-methyl	Aug 15/23	ND	µg/L	No
Benzene	Aug 15/23	ND	µg/L	No
Benzo(a)pyrene	Aug 15/23	ND	µg/L	No
Bromoxynil	Aug 15/23	ND	µg/L	No
Carbaryl	Aug 15/23	ND	µg/L	No
Carbofuran	Aug 15/23	ND	µg/L	No
Carbon Tetrachloride	Aug 15/23	ND	µg/L	No
Chlorpyrifos	Aug 15/23	ND	µg/L	No
Diazinon	Aug 15/23	ND	µg/L	No
Dicamba	Aug 15/23	ND	µg/L	No
1,2-Dichlorobenzene	Aug 15/23	ND	µg/L	No
1,4-Dichlorobenzene	Aug 15/23	ND	µg/L	No
1,2-Dichloroethane	Aug 15/23	ND	µg/L	No
1,1-Dichloroethylene (vinylidene chloride)	Aug 15/23	ND	µg/L	No
Dichloromethane	Aug 15/23	ND	µg/L	No
2-4 Dichlorophenol	Aug 15/23	ND	µg/L	No



Gowanstown Drinking Water System
2025 Annual and Summary Report

Summary of Organic parameters tested during this reporting period or the most recent sample results				
2,4-Dichlorophenoxy acetic acid (2,4-D)	Aug 15/23	ND	µg/L	No
Diclofop-methyl	Aug 15/23	ND	µg/L	No
Dimethoate	Aug 15/23	ND	µg/L	No
Diquat	Aug 15/23	ND	µg/L	No
Diuron	Aug 15/23	ND	µg/L	No
Glyphosate	Aug 15/23	ND	µg/L	No
HAA (running annual average)	2023	8.13	µg/L	No
Malathion	Aug 15/23	ND	µg/L	No
Metolachlor	Aug 15/23	ND	µg/L	No
Metribuzin	Aug 15/23	ND	µg/L	No
Monochlorobenzene	Aug 15/23	ND	µg/L	No
Paraquat	Aug 15/23	ND	µg/L	No
Pentachlorophenol	Aug 15/23	ND	µg/L	No
Phorate	Aug 15/23	ND	µg/L	No
Picloram	Aug 15/23	ND	µg/L	No
Polychlorinated Biphenyls(PCB)	Aug 15/23	ND	µg/L	No
Prometryne	Aug 15/23	ND	µg/L	No
Simazine	Aug 15/23	ND	µg/L	No
THM (running annual average)	2024	15.4	µg/L	No
Terbufos	Aug 15/23	ND	µg/L	No
Tetrachloroethylene	Aug 15/23	ND	µg/L	No
2,3,4,6-Tetrachlorophenol	Aug 15/23	ND	µg/L	No
Triallate	Aug 15/23	ND	µg/L	No
Trichloroethylene	Aug 15/23	ND	µg/L	No
2,4,6-Trichlorophenol	Aug 15/23	ND	µg/L	No
Trifluralin	Aug 15/23	ND	µg/L	No
Vinyl Chloride	Aug 15/23	ND	µg/L	No
2 methyl-4-chlorophenoxyacetic acid (MCPA) Reported as MCPA on analysis	Aug 15/23	ND	µg/L	No

*ND = Not detected



Gowanstown Drinking Water System
2025 Annual and Summary Report

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.				
Parameter	Sample Date	Result Value	Unit of Measure	ODWS Standard
Arsenic – Q1	Feb 10/25	9.2	µg/L	10
Arsenic – Q2	May 12/25	8.8	µg/L	10
Arsenic – Q3	Aug 11/25	9.2	µg/L	10
Arsenic – Q4	Nov 10/25	9.1	µg/L	10



Part 2 – SUMMARY REPORT (as required by O. Reg. 170/03, Schedule 22)

Non-Compliance with Legislations, Regulations, Approvals & Orders		
<p>The Gowanstown Drinking Water System is governed by, and must operate in accordance with, the following Acts and Regulations:</p> <ul style="list-style-type: none"> • Safe Drinking Water Act 2002; <ul style="list-style-type: none"> ○ O. Reg 128/04 – Certification of Drinking Water System Operators ○ O. Reg 170/03 – Drinking Water Systems ○ O. Reg 169/03 – Ontario Drinking Water Quality Standards • Environmental Protection Act, where applicable; • Clean Water Act, where applicable; <p>During this period, the Facility was operated in full compliance with the Act, the regulations and the Facility’s license and permit save and except for the following:</p>		
Requirement	Duration of Failure	Measures to Correct the Failure
<p>There were no non-compliances in 2025.</p>		



System Capability

Month	Average Flow (m ³ /d)	Maximum Flow (m ³ /d)	Total Monthly Flow (m ³ /d)	Maximum Flow Rate (L/min)	System Capacity
January	9.92	11.67	307.57	84	71.0 m ³ /day
February	10.13	13.42	283.53	83	
March	10.73	16.14	332.65	86	
April	11.32	19.17	339.72	86	
May	12.44	24.66	385.54	87	
June	10.54	16.69	316.19	78	
July	12.88	29.33	399.17	75	
August	11.27	22.09	349.24	80	
September	10.47	15.11	314.02	82	
October	10.15	15.74	314.51	83	
November	9.78	12.48	293.28	87	
December	11.20	21.40	347.29	87	
Average	10.90		331.89	83.17	
Maximum		29.33	399.17	87	
% of Capacity	15.35	41.31			